



OPERATION PROCESSING IN POWER INTERRUPTION DETECTION (DETECTION VOLTAGE LEVEL 85%)		SELECT
瞬停検出処理(電圧検出85%)		選択
1	ABOUT 20ms OR MORE DETECTS THE POWER FAILURE. 瞬停検出 約20ms 超	MAJOR FAULT STOP 重大故障停止
2	ABOUT 5ms OR MORE DETECTS THE POWER FAILURE. 瞬停検出 約5ms 超	THE FREERUN STOP フリーラン停止
3	ABOUT 300ms OR MORE DETECTS THE POWER FAILURE. (300ms DRIVING CONTINUANCE) 瞬停検出 約300ms 超 (300ms運転継続)	MAJOR FAULT STOP 重大故障停止
		THE FREERUN STOP フリーラン停止

※ THE FREERUN STOP IS INVERTER RESTART IN VOLTAGE RECOVERY.
※ フリーラン停止は復電後再起動します。

VOLTAGE	TERMINAL
AC220V	U1
AC200V	U2

Control Stack Board

制御スタック
CONTROL STACK
ST1
<201>
RKJS1SXX-2443A

19#07R03B
19#08B19B

Revisions	Drawn	2019-07-03	T. IWATA	Approved	Title	INVERTER CUBICLE 制御スタック CONTROL STACK(1)	Ref. Drawing No.	SH416231	20
	Checked	2019-07-03	M. INA						
	① 一部変更	2019-07-08	岩田 伊奈 仲井						
Fuji Electric Co., Ltd.							MF3965F1A		20